



GOVERNMENT OF TRIPURA
DIRECTORATE OF FIRE & EMERGENCY
SERVICES
AGARTALA : TRIPURA



website: www.fireservice.tripura.gov.in

Email: dg.fire-@gov.in

Phone: 0381-232-6451

Dated: 10/05/2022

No: FSCTFES/2022/00013

Sub: FIRE SAFETY CERTIFICATE

Certified that the building or premises as mentioned below have complied with the fire prevention and fire safety requirements in accordance with the conditions laid down in the relevant portions of Part-IV of the latest National Building Code and the Tripura Building Rules and that the building/ premises is fit for occupancy class Educational for a period of 3 (three) year(s) in accordance with renewal from time to time.

Name of the Applicant:-	Sujit Dasgupta			
Name of Owner with Plot details:-	S. No.	Owner Name and Address		
	1.	দং সুজিত কুমার দাস পিতা: শ্যামল কুমার দাস ম্ৰাং - মঠ চৌমহনী আগর তলা		
Name of the Property/ Organization/ Commercial establishment	S. No.	Plot No	Total Area	Classification
	1.	6038/18080	1.2	----
Address of the Building/ Premises:-	Modern Hr. Sec. School			
	Modern Hr. Sec. School, Datta Palli Habitation, Malaynagar Gram Panchayat, Dukli Block, Post Office Renters Colony B.O - 799004, West Tripura District, Tripura.			

Director,
Fire & Emergency Services,
Or Authorized Signatory
Tripura : Agartala

This certificate will expire on 10/05/2025

(S. DASGUPTA)
Principal
Modern Hr. Sec. School,
Malaynagar, Dattapalli,
Tripura (W).

9/5/23
Secretary,
Swami Vivekananda Educational & Research Trust
54th Chowmihani, Jail Road
Agartala, Tripura West

Conditions for the Validity of Fire Safety Certificate (NOC).

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. There should not be any change of Trade for which this License has been issued.
3. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the Fire Safety Certificate stands null and void.
4. Water reservoir should always be kept full up to brim.
5. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
6. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- 7.

Digitally signed by Rakesh Debbarna
Date: 2022.05.10 05:37:04 +05:30